



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
DOUBLE STRAP SERVICE CLAMPS**

USING DEPARTMENT: Austin Water **PREPARED BY:** Bill Flynn, P.E. **ISSUED:** 01/23/78
REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 04/01/24

DESCRIPTION: Double strap service clamps (tapping sleeves) shall comply with the following:

1. 12-mil nylon-coated ductile iron saddle
2. Flat stainless steel straps and stainless steel bolts
3. Sizes are 4" x ¾" through 12" x 2" for DI or AC pipe O.D.
4. AWWA C800, where applicable

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/03/94	SMITH-BLAIR, INC. P.O. Box 5337 Texarkana, TX 75505	Series 317	W. Flynn
01/03/94	ROMAC INDUSTRIES, INC. 1064 Fourth Ave. South Seattle, WA 98134	Style 202NS	W. Flynn
04/03/95	FORD METER BOX COMPANY P.O. Box 443 Wabash, IN 46992-0443	FC202	W. Flynn
01/03/94	POWERSEAL PIPELINE PRODUCTS, CO. 1619 Eastside Drive Wichita Falls, TX 76307	Series 3417	W. Flynn
01/02/96	MUELLER COMPANY 500 West Eldorado Street Decatur, IL 62525	DN2S Series DR2S Series	R. Lamb
01/02/97	JCM INDUSTRIES, INC. P.O. Box 1220 Nash, TX 75569-1220	406 Coated Wide Body (See Note 2)	W. Flynn
10/01/03	DRESSER PIPING SPECIALTIES 41 Fisher Avenue Bradford, PA 16701	Style 291	R. Lamb
10/01/08	A.Y. McDONALD P.O. Box 508 Dubuque, IA 52004	Model 4856A	R. Lamb

NOTES:

1. Bolt opening on one side or both sides of body must fully enclose strap bolts.
2. Only the following service clamps are allowed for use on HDPE pipe: JCM 406 Coated Wide Body. Service clamps that require spring washer are not allowed for use with HDPE pipe.

LATEST REVISIONS (since 01/01/12):

1. Updated to new SPL format.
2. Added Note 2.