



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for

BLOW-OFF VALVE FOR RECLAIMED WATER

USING DEPARTMENT: Water Utility **ISSUED:** 10/01/04 **REVIEWED:** 04/01/16 **REVISED:** 04/01/16

PREPARED BY: Robert Lamb, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Blow-off valve, non-freezing, self-draining, compression type with outlet having 2½ inch (63.5 mm) nozzle with National (American) Standard Fire Hose Coupling Screw Thread NFPA 1963 and nozzle cap. Factory painted purple, with “reclaimed water” cast into lid. Valve shall have cast iron box, locking lid, and ductile iron riser pipe. Principal interior operating parts shall be brass and removable from the valve for servicing without excavating the valve.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/16	FORD METER BOX CO. INC P.O. Box 443 Wabash, IN 46992-0443	Catalogue BLA-C14406-001-AWT-NL (2” angle offset ball valve w/2” MIP Inlet x 2-1/2” Hose Thread Outlet, assembled watertight w/purple cap and handle)	R. Lamb

NOTE:

1. At time of installation, installer shall re-lubricate operating mechanism and nozzle threads using lubricant recommended by the manufacturer. Substitution of other types or brands of lubricants is not permitted.